

1/ Preparing the fixture. 2/ Distance between screw holes (D). Mounting screws not included. 3/ Recommended accessory : IP68 junction box, F3.A3 for On/Off.

Dimensions: 143.5, 279, 23.6, 9, 6.2, 3.4, 92.5, 31mm, 6.2, 3.4, 92.5, 31mm.

Accessories: M4x12 x2, F3.A3 x3, F3.A

Temperature: Tc max=85°C Risk group(EN 62471:2008)=0

Installation cable must support 110°C temperature. Feeding cable must be cable pipe 3x1 mm². Installation may require advice.

Warning: No open flame.

Tc max=85°C Risk group(EN 62471:2008)=0


Installation cable must support 110°C temperature. Feeding cable must be cable pipe 3x1 mm². Installation may require advice.

General safety instructions: information on restrictions related to use of the light fixtures (class, IP, etc), can be found both on the fixture label and on our website at www.rovasi.com.

The wiring schematics can be found on page 2 of the document.

ELECTRONIC EQUIPMENT:

S: On/Off.







5.5W / 250mA

- 322KXS.4-I1128
- 322KXS.4-I1129
- 322KXS.4-I1130
- 322KXS.4-I1131

ACCESSORIES



F3.A3
On/Off



LED technology and performance data are constantly changing. Current details should therefore be checked with ROVASI in order to ensure that its still the mostup to date reference. Updated data will be supplied on request. [31.03.2021]



BSI Cert ISO 9001:2015 - n°FM 39346
BSI Cert ISO 14001:2015 - n°EMS 55468

ROVASI S.L.
Ronda de la Font-Grossa 15
Pol. Ind. La Gavarrà
08540 Centelles | Barcelona
Spain

Contact
info@rovasi.com
www.rovasi.com
T. 34 93 881 35 12
T. 34 93 881 37 13

The light source contained in this luminaire shall only be replaced by the manufacturer or his service agent or a similar qualified person.


Installation instructions. Mains supply wires

- Wiring type and cross section
- Solid wire a cross section of $1,5\text{mm}^2$. Strip 8,5-9,5 mm of insulation from the cables to ensure perfect operation of terminals.
- Use one wire for each terminal connector only.
- Use each strain relief channel for one cable only.
- Installation may require advice from a qualified person.
- Single lights apt for inner use outer.

Wiring guidelines

- Cable length is 190mm.
- Short circuit, overload, open circuit and thermal protection.

Wiring diagram S: On/Off



Input / Output terminal

